Evaluation of ground motion coherency function using probabilistic dynamic analysis

*Hak-sung Kim¹⁾, Yonghee Lee²⁾, and Jeongseon Park³⁾

^{1), 2), 3)} Central Research Institute, Korea Hydro and Nuclear Power Co., Ltd., 70 Yuseong-Daero 1312beon-gil, Yuseong-gu, Daejeon, Korea [34101]

1) haksung.kim@khnp.co.kr

ABSTRACT

The seismic soil-structure interaction can be estimated more precisely with ground motion incoherent analysis method. For the incoherent analysis, the ground motion coherency reduction with frequency and separation distance characterized by ground motion coherency function (EPRI, 2007). The ground motion coherency function is the one of essential input parameters of the incoherent soil-structure interaction (SSI) analysis on nuclear power plant structures. Various ground motion coherency functions have been provided based on several dense seismic array data. However, the ground motion coherency function is site-specific because the ground motion incoherency is induced by the near surface scattering of seismic wave (Abrahamson, 2007; Svay, 2018). In this study, probabilistic dynamic analysis based on site-specific spatial variability was conducted to estimate the ground motion coherency function.

REFERENCES

Abrahamson, N.A. (2007), "Hard-rock coherency functions based on the Pinyon Flat array data", Draft report to EPRI, July 5th 2007.

EPRI, (2007), "Program on Technology Innovation: Validation of CLASSI and SASSI Codes to Treat Seismic Wave Incoherence in Soil-Structure Interaction (SSI) Analysis of Nuclear Power Plant Structures", Report 1015111, EPRI, Palo Alto, CA, USA.

Svay, A., (2018), "Modelling of Spatial Variability of Seismic Ground Motions for Soil-Struture Interaction Analysis", Éditions Universitaires europeennes, Beau Bassin, Mauritius.

¹⁾ Senior Researcher

²⁾ Principal Researcher

³⁾ Deputy Senior Researcher